

Colongra Power Station Monthly Summary Report February 2016

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	7/03/2016	No diesel during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	36.4	37.9	60.0	7/03/2016	Data from a period of instrument downtime excluded
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	7/03/2016	No diesel during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	39.5	42.7	60.0	7/03/2016	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	7/03/2016	No diesel during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	22.1	30.0	60.0	7/03/2016	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	7/03/2016	No diesel during the month
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	30.0	56.0	60.0	7/03/2016	

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous		39.5	60.0	7/03/2016	Data connection and calculation did not pick up all data
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous		22.4	60.0	7/03/2016	Data connection and calculation did not pick up all data
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous		30.0	60.0	7/03/2016	Data connection and calculation did not pick up all data

Corrected Data

LDP2	Nitrogen dioxide - gas	mg/m3	Continuous		42.7	60.0	12/08/2016	
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous		30.0	60.0	12/08/2016	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous		56.0	60.0	12/08/2016	