

Colongra Power Station Monthly Summary Report March 2016

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	4/04/2016	
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	37.8	38.4	60.0	4/04/2016	Annual emissions test result, 1 hour average of 34 mg/m3
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	4/04/2016	
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	36.2	37.9	60.0	4/04/2016	Annual emissions test result, 1 hour average of 46 mg/m3
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	4/04/2016	
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	29.7	31.5	60.0	4/04/2016	Annual emissions test result, 1 hour average of 30 mg/m3
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	4/04/2016	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	36.2	41.4	60.0	4/04/2016	Annual emissions test result, 1 hour average of 32 mg/m3

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
Original Data								
Corrected Data								