

Colongra Power Station Monthly Summary Report May 2016

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	1/06/2016	No diesel used during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous			60.0	1/06/2016	Normal operation did not exceed 1 hour during the month
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	1/06/2016	No diesel used during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous			60.0	1/06/2016	Normal operation did not exceed 1 hour during the month
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	1/06/2016	No diesel used during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous			60.0	1/06/2016	Normal operation did not exceed 1 hour during the month
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	1/06/2016	No diesel used during the month
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	35.7	35.7	60.0	1/06/2016	

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
Original Data								
Corrected Data								